

Jeffery C. Allen
Chair
Idaho

Ed Schriever
Idaho

Doug Grob
Montana

Mike Milburn
Montana



Northwest **Power** and **Conservation** Council

KC Golden
Vice Chair
Washington

Thomas L (Les) Purce
Washington

Ginny Burdick
Oregon

Louie Pitt, Jr.
Oregon

June 4, 2024

MEMORANDUM

TO: Council Members

FROM: Dor Hirsh Bar Gai, Power System Analyst

SUBJECT: GENESYS Enhancements and Early 2029 Adequacy Assessment Results

BACKGROUND:

Presenters: Dor Hirsh Bar Gai, John Ollis

Summary: Staff will present summaries of (1) GENESYS modeling enhancements and assumptions incorporated since 2027 adequacy assessment, and (2) the early resource adequacy assessment results for the 2029 operating year using the Council's multi-metric adequacy approach.

The enhancements include improving (1) risk representation of future hydro uncertainty, (2) renewable generation and load forecast error, and (3) WECC-wide representation of resources. For assumptions, staff modified (1) new in-region solar shapes, (2) hydro reserve allocation, (3) thermal start up costs, and (4) deficit interpretation.

Early findings from the 2029 assessment indicate that keeping on track with the implementation of the 2021 Power Plan resource strategy - including holding 6,000 MW of balancing up reserves - alongside system changes in the region of announced non-retirements of thermal plants and expanded transmission capability, will result in an adequate power supply in 2029, despite forecasted load growth from transportation electrification and data centers.

GENESYS Enhancements & Early 2029 Adequacy Assessment Results

Council Meeting
June 11, 2024

Dor Hirsh Bar Gai
John Ollis



Northwest **Power** and
Conservation Council

Agenda


- Review of GENESYS Enhancements & Assumptions
- Reminder of Adequacy Assessment
- 2029 Market Buildout
- 2029 Assessment Scenarios & Results

GENESYS Enhancements & Assumptions



Northwest **Power** and
Conservation Council

Modeling Updates



Enhancements



- Future value of hydro
- Fine tuned forecast error
- WECC-wide resources



Assumptions

- New in-region solar shapes
- Hydro reserve allocation
- Thermal Startup costs
- Interpreting deficits

Future Value of Hydro



Goal


- Enhance representation of hydro uncertainty risk to mitigate over optimization

Status

- Created functionality to isolate risk-informed hydro inventory allotment



Fine-Tuned Forecast Error




Goal

- Improve representation of forecast error by renewable resource type and load to better capture system risk

Status


- Disaggregated forecast error values for wind, solar, and load
- Re-evaluate error parameters as needed towards Plan

WECC-wide resources



Goal


- Represent market risk of renewable generation across the WECC (due to forecast error)




RAAC
Requested

Status

- Modeled ~2,000 individual renewable resources
- Need to evaluate tradeoff of this assumption (run time vs impact)



New In-Region Solar Shapes




Goal



- Improve geographic representation of solar in the PNW

Status



- Created solar capacity factors by Balancing Authority



Examples of Idaho Power and PGE solar capacity factor comparison



Existing Hydro & Thermal System





Goal

- Improve representation of existing hydro and thermal utilization

Status

- Applied limitations on hydro reserve allocation by plant
- Incorporated thermal start up costs

Interpreting Deficits from the Model




Goal

- Utilize true-up stage for reporting model deficits and calculating adequacy metrics

Status

- Resolved true-up issue

U.S. Commitments Reminder




Spill operations in Lower Snake and Lower Columbia updated according to Appendix B of US Commitments



Based on follow-up conversations, reviewing and considering improvements we can make to representing these operations, specifically treatment of reserves

Adequacy Assessments

What Are Adequacy Assessments?



Objectives for the 2029 Adequacy Assessment

- The two primary objectives for this assessment are as follows:

1. Provide the 2nd look of whether the 2021 Power Plan continues to provide appropriate direction to ensure an adequate system 5-years out
2. Test utilization of new multi-metric approach for characterizing system adequacy

To facilitate achieving those objectives:

- **staff will share modeling results** relative to the new metrics
- **Staff is seeking member discussion** on what the results mean relative to the 2021 Power Plan strategy


Adequacy Approach

- Adequacy studies simulate the NW power system to meet NW load
- In each simulation, representing one year, a simulated model shortfall event occurs over a time period when load cannot be served by resources in the model
- However, a shortfall in the model **does not** necessitate an actual curtailment
 - Rather, it signals non-modeled emergency measures are necessary to avoid curtailment:

Type 1: Within utility control

- High operating cost resources not in utility's active portfolio
- High-priced market purchases over max import limits
- Load buy-back provisions
- Industry backup generators

Model shortfall;
no emergency
resources are
in the model



Type 2: Extraordinary measures

- Official's call for conservation
- Reduce less essential public load (e.g., gov't buildings, streetlights, etc.)
- Utility emergency load reduction protocols
- Curtail F&W hydro operations

- Adequacy metrics evaluate shortfalls to inform risk of using emergency measures

The Metrics and Thresholds

Protection against frequent deficits



LOLEV

0.1 in summer
0.1 in winter
+ report annual

Protection against tail-end (extreme) deficits




Duration VaR 97.5

8-hour



Peak VaR 97.5

1,200 MW
+ report NVaR



Energy VaR 97.5

9,600 MW
+ report NVaR

2029 Market Buildout

Out of Region Market Buildout Update

Initial adequacy results are informed by market fundamentals per outside the region market resources with buildout from AURORA

1. Resource buildout challenges (modified timeline and enhancement expectations)
2. Recommend draft buildout to inform adequacy assessment results

Resource Buildout Challenges

- AURORA Issues completing buildout.
 - Currently working with Energy Exemplar debugging
- Possible draft market buildout could be improved but deemed reasonable by the RAAC for the assessment.

Overview of Input Assumption Change Status

Already Implemented Inputs

- Updated to 2023-2024 vintage out of region load forecast
- Updated gas prices to December 2023 Council Fuel Price forecast

Draft Input Information

- Updated new resource costs to reflect IRA provisions (mostly ITC/PTC changes)
- Updated zonal transfer to reflect updated limits for pricing run (not for buildout)
- Updated new resource information to include Long Duration Energy Storage (LDES)
- Per SAAC suggestion, updated timing on Proxy Clean resource availability from 2035 to 2030

Yet to be Implemented Updates (On Hold waiting for an AURORA fix)

- Existing resources (still 2022 update vintage)
- Any modification of IRA interpretation
- Additional planned increases in transmission capability

Solar, Solar Plus Storage, Battery, LDES and Pumped Storage Build Comparisons (*installed capacity in megawatts*)



| Year | Draft 2024 Baseline | 2022 Baseline | 2021 Plan Baseline |
|------|---------------------|---------------|--------------------|
| 2025 | 2,153 | 21,528 | 51,538 |
| 2030 | 14,355 | 42,206 | 89,838 |
| 2035 | 15,355 | 45,141 | 100,357 |
| 2040 | 17,355 | 56,494 | 135,054 |
| 2045 | 19,200 | 75,890 | 147,554 |

| Year | Draft 2024 Baseline | 2022 Baseline | 2021 Plan Baseline |
|------|---------------------|---------------|--------------------|
| 2025 | 0 | 23,386 | 46,600 |
| 2030 | 2,261 | 60,503 | 86,600 |
| 2035 | 5,301 | 60,503 | 145,500 |
| 2040 | 20,156 | 63,429 | 179,800 |
| 2045 | 39,906 | 63,429 | 198,000 |

| Year | Draft 2024 Baseline | 2022 Baseline | 2021 Plan Baseline |
|------|---------------------|---------------|--------------------|
| 2025 | 27,813 | 13,634 | 6,004 |
| 2030 | 35,875 | 13,940 | 6,004 |
| 2035 | 46,903 | 13,965 | 6,004 |
| 2040 | 104,016 | 14,861 | 6,004 |
| 2045 | 129,751 | 18,390 | 6,055 |

| Year | Draft 2024 Baseline | 2022 Baseline | 2021 Plan Baseline |
|------|---------------------|---------------|--------------------|
| 2025 | 0 | 0 | 0 |
| 2030 | 1,300 | 0 | 4,900 |
| 2035 | 1,300 | 2,200 | 5,650 |
| 2040 | 2,840 | 2,200 | 6,050 |
| 2045 | 3,840 | 2,200 | 9,690 |

| Year | Draft 2024 Baseline |
|------|---------------------|
| 2025 | 0 |
| 2030 | 5,913 |
| 2035 | 17,943 |
| 2040 | 34,321 |
| 2045 | 46,214 |

Wind, Gas, Offshore Wind and Proxy Clean Build Comparisons (installed capacity in megawatts)



| Year | Draft 2024 Baseline | 2022 Baseline | 2021 Plan Baseline |
|------|---------------------|---------------|--------------------|
| 2025 | 2,211 | 12,155 | 16,775 |
| 2030 | 16,031 | 18,634 | 35,175 |
| 2035 | 16,031 | 27,906 | 37,063 |
| 2040 | 30,222 | 38,221 | 43,657 |
| 2045 | 36,887 | 69,769 | 51,481 |

| Year | Draft 2024 Baseline | 2022 Baseline | 2021 Plan Baseline |
|------|---------------------|---------------|--------------------|
| 2025 | 4,523 | 7,305 | 11,351 |
| 2030 | 11,403 | 14,332 | 14,873 |
| 2035 | 14,185 | 14,806 | 16,058 |
| 2040 | 14,614 | 15,235 | 16,532 |
| 2045 | 16,330 | 15,235 | 16,532 |

| Year | Draft 2024 Baseline | 2022 Baseline | 2021 Plan Baseline |
|------|---------------------|---------------|--------------------|
| 2025 | 0 | 0 | 0 |
| 2030 | 0 | 0 | 6,463 |
| 2035 | 0 | 0 | 7,663 |
| 2040 | 10,000 | 0 | 10,000 |
| 2045 | 10,000 | 0 | 10,000 |

| Year | Draft 2024 Baseline | 2022 Baseline | 2021 Plan Baseline |
|------|---------------------|---------------|--------------------|
| 2025 | 0 | 0 | 0 |
| 2030 | 684 | 1,368 | 0 |
| 2035 | 684 | 3,420 | 0 |
| 2040 | 684 | 3,420 | 0 |
| 2045 | 4,104 | 7,524 | 0 |

Draft Buildout in 2029 Outside the Region

- Canada
 - Other than Site C in BC, all builds are in Alberta
 - 6 GW of solar, 15.6 GW of wind, 3.4 GW of natural gas
- California
 - 17 GW of 4-hour storage and 1.8 GW of LDES
- Desert Southwest (NV, AZ, NM)
 - 450 MW of solar, 470 MW of natural gas, 5.7 GW of 4-hour storage, 900 MW of LDES
- Baja
 - 2.3 GW of natural gas, 1.5 GW of 4-hour storage, 200 MW LDES
- Mountain West (UT, CO, WY)
 - 1.1 GW of solar, 2.4 GW of gas, 6.9 GW of storage

Observations

- More storage resources than energy resources added in early years.
 - Further modifications to IRA implementation may cause larger VER build early but unclear
- Some coal to gas plant conversions seems to be deferring the needs for builds to maintain planning reserve margins and reducing early need for new gas build
- The buildout will likely change for the market study, but likely to be larger outside the region. A larger buildout would likely only improve adequacy results, so we recommend moving forward with this buildout for the 2029 assessment to stick to the timeline.

Early 2029 Adequacy Assessment Results

2021 Power Plan Resource Strategy reminder



Existing System: Increase Reserves

To reduce regional needs and support integration of renewables, the region needs to double the assumed reserves. This can most cost-effectively be done through more conservative operation of the existing system (both thermal and hydro units).



Renewables: At least 3,500 MW by 2027

Renewables are recommended due to their low costs, interruptibility, and carbon reduction benefits. Long-term build out will impact the transmission system and should be done mindful of the cumulative impacts of the new resources.



Energy Efficiency: 750-1,000 aMW by 2027

Significantly less acquisition than prior plan due being less cost-competitive, a slower build resource, not inherently dispatchable, and sensitive to market prices. Efficiency that supports system flexibility is most valuable.



Demand Response: Low-Cost Capacity

Highest value products are those that can be regularly deployed at a low-cost and with minimal to no impact on customer. The Council identified demand voltage regulation and time of use rates as two products, estimating 720 MW of potential.


The 2029 Resource Strategy – the Reference

- Our goal for this assessment was to assume the same trajectory of the strategy used in the reference case for the 2027 Adequacy Assessment

| Portfolio | 2029 Adequacy Assessment | 2027 Adequacy Assessment |
|------------|--------------------------|--------------------------|
| Renewables | 6,600 MW | 5,900 MW |
| EE | 1,300 aMW | 1,000 aMW |
| DR | 720 MW | 720 MW |
| Reserves | 6,000 MW | 6,000 MW |

2021 Plan Buildout Trajectories

Not shown here: Early coal retirement, with limits on gas, and the deep decarbonization scenario resulted in the highest builds (~36 GW in 2041)



Other System Changes Across all Studies

- Announced changes to several thermal plants not retiring (~1,480 MW)
 - Valmy 1 & 2 (138.6 & 134 MW)
 - Bridger 1 & 2 (~1,200 MW)
 - Currently modeled same as before → possible new modeling as gas conversion when new information will be available
- Expanded transmission capacity
 - 12,700 MW of added transmission capacity
 - Only 1,000 MW in region (B2H)

| Planned Transmission | New Capacity (MW) | Path | Online Date | GENESYS Buses | Existing Today (MW) | New 2029 capacity (MW) |
|----------------------|-------------------|-------------------------|-------------|------------------------|---------------------|------------------------|
| Ten West Link | 3,200 | SCE to APS | 2024 | So_Cal to Arizona | 1,400 | 4,600 |
| SunZia | 3,000 | PNM to APS | 2026 | New Mexico to Arizona | 1,700 | 4,700 |
| Transwest Express | 3,000 | WAPA Wyoming to PACE UT | 2027 | wapa RM to PAC_UT | 650 | 3,650 |
| | 1,500 | PACE UT to Nev South | 2027 | PAC_Ut to Nevada South | 250 | 1,750 |
| SWIP North | 1,000 | IP to North Nevada | 2027 | IP to north Nevada | 350 185 | 1,350 1,185 |
| B2H | 1,000 | IP to BPA_OR | 2026 | IP to BPA_OR | 2,000 | 3,000 |



Potential Scenarios

- Reference
- Higher data center load (in region)

Developed, simulated, analyzing,
discussing today

- In-region gas supply limitations
- Earlier availability of transmission (reconductoring in region)
- Delayed availability of transmission and emerging tech in WECC
- Emission pricing

Pushed to
9th Plan

- Alternative Trajectories within Resource Strategies

In progress


Incremental Load Differences in 2029

| | EE Savings aMW | EV Loads aMW | Data Center Loads aMW |
|-----------------------------------|-------------------|-----------------|--------------------------|
| 2029 Reference scenario | 1,300 | 1,048 | 2,386 |
| 2029 High Data Center scenario | 1,300 | 1,048 | 3,976 |

Consideration of Alternative Trajectories within the Resource Strategy

Two alternative trajectories depending on results of the Reference study

- Testing the low end of the cost-effective range of EE
 - ~1,000 aMW of EE by 2029, instead of the 1,300 aMW tested in the reference case
- Testing ~12,000 MW of renewables in 2029 instead of 6,600 MW
 - Planned renewable buildout for 2029 is 11,907 MW (within 2021 Power Plan range)



Draft Results

4 event-years
2.2% LOLP

24 event-years
13.3% LOLP

Adequate

Non-Adequate

| | Metric | Threshold | Reference | High Data Center |
|-----------------------------------|-------------------|-----------|-----------|------------------|
| Frequency | Winter LOLEV | 0.1 | 0.022 | 1.294 |
| | Summer LOLEV | 0.1 | 0.017 | 0.3 |
| Duration | Duration VaR 97.5 | 8 | 0 | 20.6 |
| Magnitude | Peak VaR 97.5 | 1,200 | 0 | 3,076 |
| | Energy VaR 97.5 | 9,600 | 0 | 196,324 |
| Reported metrics (non-binding) | Annual LOLEV | 0.1 | 0.05 | 1.644 |
| | Peak NVaR 97.5 | ~3%* | 0 | 9% |
| | Energy NVaR 97.5 | ~0.0052%* | 0 | 0.09% |

LOLEV

Total events:

9 events

296 events

| Metric | Months | Threshold | Reference | High Data Center |
|--------------|---------|-----------|-----------|------------------|
| Winter LOLEV | Dec-Feb | 0.1 | 0.022 | 1.294 |
| Summer LOLEV | Jun-Aug | 0.1 | 0.017 | 0.3 |
| Annual LOLEV | All | 0.1 | 0.05 | 1.644 |
| Spring LOLEV | Mar-May | 0.1? | 0.011 | 0.039 |
| Fall LOLEV | Sep-Nov | 0.1? | 0.000 | 0.011 |

Food for thought:
 as discussed, relying on winter and summer without an annual perspective
 overlooks potential spring and fall deficits.

Quick Reminder on Climate Studies


Study Simulations = 180 years → 60 for each climate scenario → 10 water-load years * 6 regional wind profiles

In other words: 10 water-load combinations that repeat 6 times, once for each different regional wind profile

| Scenario | Winter Hydro Generation | Summer Hydro Generation | Winter HDDs | Summer CDDs |
|------------|-------------------------|-------------------------|-------------|-------------|
| CanESM (A) | | <i>low</i> | <i>low</i> | <i>high</i> |
| CCSM (C) | <i>high</i> | <i>low</i> | | |
| CNRM (G) | <i>low</i> | <i>high</i> | <i>high</i> | <i>low</i> |

 High loads and low water conditions might cause adequacy events

Simulation Scenario Cipher



(3 scenarios)

Cimate Scenario_ **Wind Profile**, **Hydro-Load Profile**



A
C
G

(6 profiles)



0
1
2
3
4
5

(10 profiles)



0
1
2
3
4
5
6
7
8
9

Recall that a VaR 97.5 value of 0 does not mean no shortfalls;
rather it is a probabilistic representation signaling the shortfall risk 39 out of 40 years

Events in Reference Scenario

Maximum event
duration and peak

| event_index | Sim_Scenario | Sim_scenario_event_index | Month | Day | event_duration (hour) | event_max (MW) | event_sum (MWh) |
|-------------|--------------|--------------------------|-------|-----|-----------------------|----------------|-----------------|
| 1 | A_40 | 1 | 7 | 13 | 1 | 525 | 525 |
| 2 | C_31 | 1 | 3 | 30 | 1 | 46 | 46 |
| 3 | G_5 | 1 | 7 | 18 | 1 | 27 | 27 |
| 4 | G_33 | 1 | 1 | 17 | 4 | 960 | 3,368 |
| 5 | G_33 | 2 | 1 | 18 | 1 | 589 | 589 |
| 6 | G_33 | 3 | 1 | 19 | 1 | 844 | 844 |
| 7 | G_33 | 4 | 1 | 19 | 1 | 899 | 899 |
| 8 | G_33 | 5 | 5 | 27 | 1 | 359 | 359 |
| 9 | G_33 | 6 | 7 | 23 | 1 | 222 | 222 |

Maximum annual energy 6,281 MWh

Main challenge is one simulation:
climate scenario G_33

Major Shortfall Events in High DC Scenario

| | event_index | Sim_Scenario | Sim_scenario_ event_index | Month | Day | event_ duration (hour) | event_ max (MW) | event_ sum (MWh) | Max energy rank |
|-------------------------------|-------------|--------------|------------------------------|-------|-----|------------------------------|-----------------------|------------------------|-----------------------|
| Longest Duration Events | 286 | G_53 | 7 | 1 | 16 | 119 | 1,096 | 105,349 | 1st |
| | 265 | G_43 | 3 | 1 | 16 | 48 | 1,096 | 46,151 | |
| | 242 | G_33 | 4 | 1 | 16 | 45 | 1,096 | 41,667 | |
| Highest Peak Events | 191 | A_56 | 14 | 12 | 27 | 19 | 8,863 | 61,763 | 2nd |
| | 192 | A_56 | 15 | 12 | 28 | 9 | 8,407 | 38,898 | |
| | 189 | A_56 | 12 | 12 | 26 | 17 | 6,688 | 61,604 | 3rd |

Events in High Data Center

Scenario A:
More events (226),
greater peaks and energy

Scenario G:
Longest events,
single greatest energy deficit

| Scenario | Event frequency | Event Duration | | Event Peak | | Event Energy | |
|----------|-----------------|----------------|-----|------------|-------|--------------|---------|
| | | Average | Max | Average | Max | Average | Max |
| A_16 | 25 | 6.4 | 18 | 1,796 | 6,117 | 10,414 | 51,440 |
| A_26 | 51 | 4.0 | 16 | 1,193 | 4,392 | 5,017 | 32,118 |
| A_29 | 1 | 1.0 | 1 | 38 | 38 | 38 | 38 |
| A_31 | 1 | 1.0 | 1 | 93 | 93 | 93 | 93 |
| A_36 | 45 | 3.9 | 22 | 1,576 | 6,440 | 6,147 | 51,200 |
| A_37 | 1 | 1.0 | 1 | 455 | 455 | 455 | 455 |
| A_48 | 2 | 1.0 | 1 | 496 | 788 | 496 | 788 |
| A_56 | 48 | 4.9 | 19 | 2,164 | 8,863 | 9,198 | 61,763 |
| A_6 | 51 | 5.0 | 22 | 1,234 | 5,500 | 5,787 | 38,044 |
| A_60 | 1 | 1.0 | 1 | 454 | 454 | 454 | 454 |
| C_12 | 1 | 1.0 | 1 | 1,217 | 1,217 | 1,217 | 1,217 |
| C_19 | 1 | 1.0 | 1 | 199 | 199 | 199 | 199 |
| C_34 | 2 | 1.0 | 1 | 289 | 296 | 289 | 296 |
| C_56 | 4 | 1.5 | 3 | 270 | 537 | 537 | 1,606 |
| G_16 | 1 | 2.0 | 2 | 551 | 551 | 1,101 | 1,101 |
| G_33 | 23 | 5.8 | 45 | 730 | 1,096 | 4,544 | 41,667 |
| G_40 | 1 | 2.0 | 2 | 436 | 436 | 804 | 804 |
| G_43 | 14 | 9.4 | 48 | 826 | 1,096 | 7,312 | 46,151 |
| G_48 | 2 | 1.5 | 2 | 1,209 | 1,621 | 1,417 | 1,621 |
| G_49 | 1 | 1.0 | 1 | 331 | 331 | 331 | 331 |
| G_53 | 15 | 10.5 | 119 | 698 | 1,096 | 8,702 | 105,349 |
| G_55 | 1 | 1.0 | 1 | 34 | 34 | 34 | 34 |
| G_60 | 1 | 1.0 | 1 | 351 | 351 | 351 | 351 |
| G_8 | 3 | 1.0 | 1 | 200 | 485 | 200 | 485 |

G challenging years - 33, 43, and 53

“A” challenging years - 16, 36 , and 56 (6, 26)
All have similar low water throughout the year

High Data Center Monthly Events

More **summer** and **winter** challenges

| Scenario | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Dec |
|----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| A_16 | 13 | 1 | | | | | | 5 | | 6 |
| A_26 | 11 | 8 | | | | 1 | | 8 | | 23 |
| A_29 | | | | 1 | | | | | | |
| A_31 | | | | | 1 | | | | | |
| A_36 | 13 | 12 | | | | | 1 | 12 | | 7 |
| A_37 | | | | | | | | 1 | | |
| A_48 | | | | | | | | 1 | 1 | |
| A_56 | 22 | 6 | | | 1 | | | 4 | | 15 |
| A_6 | 16 | 11 | | | | | | 8 | | 16 |
| A_60 | | | | | | | 1 | | | |
| C_12 | | | 1 | | | | | | | |
| C_19 | | | | | 1 | | | | | |
| C_34 | | | | | | 1 | 1 | | | |
| C_56 | | | | | | 4 | | | | |
| G_16 | | | | | | 1 | | | | |
| G_33 | 23 | | | | | | | | | |
| G_40 | | | | | | | 1 | | | |
| G_43 | 14 | | | | | | | | | |
| G_48 | 1 | | | | | | | 1 | | |
| G_49 | | | | | | | | | 1 | |
| G_53 | 15 | | | | | | | | | |
| G_55 | | | | | | | 1 | | | |
| G_60 | | | | | | | | 1 | | |
| G_8 | | | 1 | | 1 | | | 1 | | |

Discussion Points

- The studies encompass a wide range of hydro, load, and renewable generation profile combinations.
- The risk of low wind generation is captured across a variety of hydro and load conditions → and poses adequacy challenges in limited scenarios

Reference Case

- Limited adequacy risk associated with one scenario (G_33) having normal winter hydro generation coupled with high loads and low wind generation
- However, similar hydro and load conditions had no adequacy issues across other wind generation profiles (G_3, 13, 23, 43, 53)

Higher Data Center Load Case

- Increased loads caused adequacy issues not present in the Reference with similar hydro & wind conditions (G_43, 53)
- However, other similar coupled hydro and wind conditions remain with no adequacy challenges due to increased loads (G_3, 13, 23)
- Increased loads worsen winter and summer adequacy challenges across additional climate scenarios (mostly A, a bit in C) not observed in the Reference

Overall Finding

- Assuming the reference case is the trajectory:
 - Continued implementation of the strategy, including ensuring sufficient reserves and acquiring another two years of energy efficiency and renewables, not retiring thermal plants, and expanded transmission capacity offset the adequacy challenge of increased loads of anticipated data centers and EV electrification
- If the higher data center case is more likely:
 - The ~1,600 MW of increased load associated with **additional** data center load growth above the reference case causes adequacy challenges
 - The plan is to study the impact and resource strategy associated with increased load uncertainty in the upcoming Power Plan.


Early 2029 Adequacy Assessment Results Winter Event Example

2029 Adequacy Assessment Reference Case – Scenario 33 Simulated Shortfalls in January




Simulated shortfalls in the evening, during a period of very high peak loads

2029 Adequacy Assessment Reference Case – Scenario 33 Load Resource Balance




Multiple days with high peak loads in morning and evening. Why are the simulated shortfalls during the lower evening peak?

2029 Adequacy Assessment Reference Case – Scenario 33 Market Reliance




Market reliance limit binding most of the way through event

2029 Adequacy Assessment Reference Case – Scenario 33 Market Reliance




Market prices indicate more market available during the event in SW and Mountain West

2029 Adequacy Assessment Reference Case – Scenario 33 Simulated Shortfalls




Longer and larger simulated shortfalls in hour ahead mitigated by thermal plant reserves

2029 Adequacy Assessment Reference Case – Scenario 33 Renewable Generation




Renewable generation is low during the event but also very low during some of the days leading up to the event.

2029 Adequacy Assessment Reference Case – Scenario 33 Thermal Generation



Thermal generation providing significant up reserves

2029 Adequacy Assessment Reference Case – Scenario 33 Hydro Generation




Hydro generation, while not low, impacted by fuel limitations throughout event

2029 Adequacy Assessment Renewable Generation Risk During High Load Events


Reference Case

- Scenario 33 had an adequacy issue but low wind generation
- Other scenarios that had the same load and hydro but different renewable generation and no adequacy issues.
- The market reliance limit is binding leading up to and throughout the event; however, market fundamentals show more availability outside the region



Next Steps

2029 Adequacy Assessment Timeline



Next Steps

- Run and analyze low end of EE in Alternative Trajectories
- Prepare final 2029 adequacy assessment report (Late June RAAC)
 - Including evaluation of multi-metric framework
- Present final 2029 adequacy assessment in July Council Meeting

Questions on Draft Results?

4 event-years
2.2% LOLP

24 event-years
13.3% LOLP

Adequate

Non-Adequate

| | Metric | Threshold | Reference | High Data Center |
|-----------------------------------|-------------------|-----------|-----------|------------------|
| Frequency | Winter LOLEV | 0.1 | 0.022 | 1.294 |
| | Summer LOLEV | 0.1 | 0.017 | 0.3 |
| Duration | Duration VaR 97.5 | 8 | 0 | 20.6 |
| Magnitude | Peak VaR 97.5 | 1,200 | 0 | 3,076 |
| | Energy VaR 97.5 | 9,600 | 0 | 196,324 |
| Reported metrics (non-binding) | Annual LOLEV | 0.1 | 0.05 | 1.644 |
| | Peak NVaR 97.5 | ~3%* | 0 | 9% |
| | Energy NVaR 97.5 | ~0.0052%* | 0 | 0.09% |

Questions?

Dor Hirsh Bar Gai

dhirshbargai@nwcouncil.org

John Ollis


jollis@nwcouncil.org



Appendix

Data center & chip fab forecasts

Incremental data center and fab growth forecast, 2023 to 2029



Higher case forecast, trends accelerate, closer to utility projections

Reference case forecast, based on current trends continuing

8th Plan high case forecast (data center only)

Duration (Hours)

Simulation Max
Duration Hours:

| | |
|-----|---------|
| Ref | High DC |
| 4 | 119 |
| 1 | 48 |
| 1 | 45 |
| 1 | 22 |

| Metric | Threshold | Reference | High Data Center |
|-------------------|-----------|-----------|------------------|
| Duration VaR 97.5 | 8 | 0 | 20.6 |
| Max | | 4 | 119 |

22
19
18
16
3
2
2
2
1
1
1
1
1
1
1
1
1
1

Peak (MW)

Simulation Max
Peak MW:

Ref High DC
960 8,863
525 6,440
46 6,117
27 5,500
4,392
1,621
1,217
1,096
1,096
1,096
788
551
537
485
455
454
436
351
331
296
199
93
38
34

| Metric | Threshold | Reference | High Data Center |
|---------------|-----------|-----------|------------------|
| Peak VaR 97.5 | 1,200 | 0 | 3,076 |
| Max | | 960 | 8,863 |

Energy (MWh)

Simulation Max
Energy MWh:

| Ref | High DC |
|-------|---------|
| 6,281 | 441,491 |
| 525 | 295,138 |
| 46 | 276,632 |
| 27 | 260,354 |
| | 255,857 |
| | 130,525 |
| | 104,506 |
| | 102,367 |
| | 2,835 |
| | 2,149 |
| | 1,217 |
| | 1,101 |
| | 992 |
| | 804 |
| | 599 |
| | 578 |
| | 455 |
| | 454 |
| | 351 |
| | 331 |
| | 199 |
| | 93 |
| | 38 |
| | 34 |

| Metric | Threshold | Reference | High Data Center |
|-----------------|-----------|-----------|------------------|
| Energy VaR 97.5 | 9,600 | 0 | 196,324 |
| Max | | 6,281 | 441,491 |

However, if data center load growth will be in the higher range of the forecast, the region will have insufficient resources to maintain adequacy – signaling the importance of analyzing such futures in the 9th Power Plan.

Staff will work with the Power Committee to finalize the 2029 Adequacy Assessment, including testing an additional scenario to evaluate the adequacy risk if the low end of the energy efficiency target outlined in the 2021 Power Plan is achieved instead.

Relevance: Continuously enhancing modeling and assumptions is key for Council analysis. These new enhancements and assumptions improve the analytical capabilities to better represent system operations and dynamics.

Resource adequacy is a critical component of the Council’s mandate to develop a regional power plan that “ensures an adequate, efficient, economic and reliable power supply.” To test the efficacy of the plan’s resource strategy, the Council – in cooperation with regional stakeholders – annually assesses the adequacy of the power supply with planned resource additions. The annual assessment is based on a [multi-metric adequacy approach](#) to categorize the risk of frequency, duration, and magnitude of events that is currently under evaluation by the Council since 2022 and approved in 2023, evolving past the [resource adequacy standard](#) of Loss of Load Probability (LOLP) metric used since 2011.

Workplan: B.1.3 Continued Enhancement of GENESYS operations to support periodic studies and next power plan.

A.2.4 Conduct the regional Adequacy Assessment and prepare report detailing the analysis and findings.

Background: An adequate power supply can meet the electric energy requirements of its customers within acceptable limits, considering a reasonable range of uncertainty in resource availability and in demand. Resource uncertainty includes forced outages, early retirements and variations in hydro, wind, solar and market supplies. Demand uncertainty includes variations due to temperature, economic conditions, and other factors. Resource availability and demand are also affected by environmental policies, such as those aimed at reducing greenhouse gas emissions.

In January 2023 the Council approved a transition towards a multi-metric adequacy approach with the completion of the 2027 Adequacy Assessment to 1) prevent overly frequent use of emergency measures, (2) limit the risk of long duration shortfall events, (3) limit the risk of big capacity shortfalls, and (4) limit the risk of big energy shortfalls. Frequency, duration, and magnitude metrics are used in combination of expected and tail-end event statistics, known as value at risk (VaR).