

Henry Lorenzen
Chair
Oregon

Bill Bradbury
Oregon

Phil Rockefeller
Washington

Tom Karier
Washington



Northwest Power and Conservation Council

W. Bill Booth
Vice Chair
Idaho

James Yost
Idaho

Pat Smith
Montana

Jennifer Anders
Montana

August 2, 2016

MEMORANDUM

TO: Council Members

FROM: John Fazio, Senior Systems Analyst

SUBJECT: Revised Power Supply Adequacy Assessment for 2021

BACKGROUND:

Presenter: John Fazio

Summary: In 2011, the Council adopted a methodology to assess the adequacy of the Northwest's power supply. The purpose of this assessment is to provide an early warning should resource development fail to keep pace with demand growth. The Council's standard defines an adequate power supply to have no more than a 5 percent chance of a resource shortfall in the year being assessed. This metric is commonly referred to as the loss-of-load probability (LOLP) and any future power supply with an LOLP greater than 5 percent is deemed to be inadequate.

The Pacific Northwest's power supply is expected to be adequate through 2020, however, by 2021 – with the loss of the Boardman and Centralia-1 coal plants (1,330 MW nameplate) – the LOLP rises to about 10 percent¹ and would lead to an inadequate supply without intermediate actions. These results assume that the region will continue to acquire energy

¹ Boardman and Centralia 1 coal plants are scheduled to retire in December of 2020. However, because the Council's operating year runs from October 2020 through September 2021, these two plants would be available for use during the first three months of the 2021 operating year. For this scenario, the LOLP is 7.6 percent. The Council must take into account the long term effects of these retirements and, therefore, uses the more generic study that has both plants out for the entire operating year.

efficiency savings as targeted in the Council's Seventh Power Plan, which amount to 1,400 average megawatts of savings through 2021.

Since the original assessment was completed, the announced retirement of Colstrip 1 and 2 coal plants was released. While the announcement stated that these projects would be closed no later than July of 2022, the Council felt it necessary to assess the adequacy of the power supply in 2021, should these plants close early. The combined winter peaking capacity from these plants dedicated to serve regional loads is 307 megawatts. Removing this capability in the 2021 operating year increases the LOLP to 13.2 percent. Assuming medium load growth through 2021, needed replacement capacity to ensure adequacy is a little over 1,000 megawatts for the case without the Colstrip 1 and 2 closure. With the closure, the capacity need rises to a little over 1,300 MW.

Actions to bring the 2021 power supply into compliance with the Council's standard will vary depending on the types of new generating resources or demand reduction programs that are considered. Designing a resource strategy to ensure an adequate power supply for 2021 is more appropriately done using the strategy outlined in the Council's Seventh Power Plan. In all likelihood, some combination of new generation and load reduction programs will be used to bridge the gap.

Northwest utilities, as reported in the Pacific Northwest Utilities Conference Committee's 2016 Northwest Regional Forecast have identified about 550 megawatts of planned generating capacity for 2021. However, these planned resources are not sited and licensed and are therefore, not included in the 2021 adequacy assessment. It is important to note that demand response programs could play a vital role in maintaining power supply adequacy, as reported in the Council's Seventh Power Plan.

Relevance: Besides being an early warning to ensure that the regional power supply remains adequate, the Council's adequacy standard is converted into Adequacy Reserve Margins (for both energy and capacity) that are fed into the Regional Portfolio Model to ensure that resource strategies developed by that model will produce an adequate supply.

Workplan: A.5.2. Complete Annual Adequacy Assessments

Background: Since the late 1990s, the Council has worked to develop a more robust method of assessing the adequacy of the region's power supply. In 2011 it formally adopted the loss-of-load probability (LOLP) metric as the measure to assess adequacy and set its maximum threshold at 5 percent. The Council reassesses this every year, looking at the adequacy of the power supply five years out, as an early warning to ensure that adequacy is maintained.

More Info: For more information please go to the Resource Adequacy Advisory Committee webpage:

<http://www.nwcouncil.org/energy/resource/home/>

Henry Lorenzen
Chair
Oregon

Bill Bradbury
Oregon

Phil Rockefeller
Washington

Tom Karier
Washington



Northwest Power and Conservation Council

W. Bill Booth
Vice Chair
Idaho

James Yost
Idaho

Pat Smith
Montana

Jennifer Anders
Montana

August 2, 2016

DECISION MEMORANDUM

TO: Council Members

FROM: John Fazio, Senior Systems Analyst

SUBJECT: Council Decision to Approve the 2021 Resource Adequacy Assessment

PROPOSED ACTION: Approval of the *2021 Power Supply Adequacy Assessment*

SIGNIFICANCE:

- Approving the resource adequacy assessment for 2021 meets the requirements for action item Res-8 in the Council's Seventh Power Plan, "In order to track Seventh Plan implementation and adapt as needed the Council, in cooperation with regional stakeholders, will provide: an annual resource adequacy assessment."
- Results from this analysis are used in the Council's resource strategy methodology to ensure that future strategies will provide adequate supplies.
- Results have also proven to be valuable to regional utilities (to aid in the assessments of their own resource plans) and to utility commissions who review those plans.
- Results are also shared with other electricity industry planning entities, such as the Western Electricity Coordinating Council (WECC) and the North American Electric Reliability Corporation (NERC).

BUDGETARY/ECONOMIC IMPACTS:

There are no effects on the Council's budget. Analysis supporting the adequacy assessment for the Northwest's power supply was performed by Council staff, aided by members of the Council's Resource Adequacy Advisory Committee. Preparing the final report, which includes a technical appendix, will also be done in house. There is no anticipated contract work to complete this task.

BACKGROUND:

Events such as the Western energy crisis of 2001, which led to West-wide electricity price spikes, have forced utilities and regulators to rethink their approach to planning and operating the power system. The crisis demonstrated that the public has little tolerance for high and volatile market prices over a prolonged period. It also became clear that the financial community will not lend money for power-plant construction unless developers have power contracts in hand and/or utilities have included the costs of those contracts in their rates.

In an environment where an increasing number of parties have taken on the responsibility for acquiring resources to serve regional load, a resource adequacy standard is key to ensuring overall regional sufficiency of resources to meet load at reasonable costs. The Pacific Northwest is unique, not only in the predominately hydroelectric nature of its resources, but also in the ratio of publicly-owned utilities (POUs) to investor-owned utilities (IOUs).

Monitoring and assessing regional resource adequacy is especially important in the Pacific Northwest for the following reasons:

- The ability to rely on wholesale electricity markets and surplus hydroelectric generation (in most years) can mask a condition of resource deficiency.
- The capital risk of constructing new resources in a market with substantially varying supply levels from year to year may be too great for many developers.
- There is a continuing lack of clarity about the responsibility for resource acquisition among public utilities, BPA and independent power producers.

In its Fifth Power Plan, the Council recognized the importance of developing a resource adequacy standard and implementation framework. Action items ADQ-1 and ADQ-2 in that plan called for the establishment of resource information-gathering protocol and for the development of a resource adequacy standard for the Pacific Northwest. To achieve these goals, the Council chartered the Resource Adequacy Advisory Committee (RAAC), with the intention that this group would aid the Council in developing a resource adequacy standard for the Northwest.

In December of 2011, the Council formally adopted its resource adequacy standard. This assessment of the 2021 power supply adequacy should help utilities and their regulators gauge whether they have enough resources to meet their loads under a regionally accepted measure of generation sufficiency.

ANALYSIS:

The RAAC has been aiding Council staff on this task since fall of 2013. Analysis and documents, including meeting notes, are posted on the Council's web site at <http://www.nwcouncil.org/energy/resource/Default.asp>. The RAAC is comprised of a technical work group and a policy steering committee.

During this past year, the RAAC has reviewed load forecast and resource data, including potential market supplies from within the region and imports from the Pacific Southwest. These data are input to the GENESYS model, which simulates the hourly operation of the power supply over many different future conditions. The model calculates how many of those simulated yearly operations experience at least one occurrence of a failure to meet load. The number of simulations in which at least one curtailment occurred divided by the total number of simulations yields the loss of load probability or LOLP, which must be 5 percent or less for the power supply to be deemed adequate.

ALTERNATIVES:

- One alternative would be to delay the release of this assessment for the purpose of obtaining a more comprehensive review of the data. However, RAAC members already represent a wide range of interested parties, ranging from private and public utilities, to federal agencies, utility commissioners, environmental groups, trade associations and transmission planners. All RAAC meetings were open to the public. The RAAC members support the results from this analysis but understand that some data can be improved upon. However, if the release of this report is delayed substantially, the schedule for implementing some of the action items in the Seventh Power Plan may be jeopardized.
- A second alternative would be to delay the release until certain improvements to the model can be made. Those improvements include the addition of more sub-regional “bubbles” to better address transmission limitations and to more thoroughly explore the issue of market “friction.” Other enhancements include a more detailed hourly hydro dispatch algorithm to better address capacity issues. This alternative is detailed in the Seventh Power Plan Action item ANLYS-22 and would make the model and results better but it would also effectively delay the release of adequacy assessment for several years.

ATTACHMENTS:

Attached is the Council’s report entitled, “2021 Power Supply Adequacy Assessment”

2021 POWER SUPPLY ADEQUACY ASSESSMENT

Executive Summary

The Pacific Northwest's power supply is expected to be adequate through 2020. However, with the planned retirements of four Northwest coal plants by July of 2022, the system will no longer meet the Council's adequacy standard and will have to acquire nearly 1,400 megawatts of new capacity in order to maintain that standard. This result assumes that the Council's energy efficiency targets, as identified in the Seventh Power Plan, will be achieved. Thus, it is imperative that cost-effective energy efficiency programs continue to be aggressively implemented. Beyond energy efficiency, Northwest utilities have steadily been working to develop replacement resource strategies and have reported about 550 megawatts of planned generating capacity by 2021. The additional need will be made up with the next most cost effective and implementable resources, which may include additional energy efficiency, demand response or new generating resources. The Council will reassess the adequacy of the power supply next year to keep tabs on the region's progress in maintaining an adequacy.

In 2011, the Northwest Power and Conservation Council adopted a regional power supply adequacy standard to "provide an early warning should resource development fail to keep pace with demand growth." The standard deems the power supply to be inadequate if the likelihood of a power supply shortfall (referred to as the loss-of-load probability or LOLP) is higher than 5 percent. The LOLP for the region's power supply is expected to stay under the 5 percent limit through 2020. In 2021, with the loss of 1,330 megawatts of capacity from the Boardman and Centralia 1 coal plants (slated to retire in December of 2020), the LOLP rises to 10 percent.¹ In this scenario, the region will need a little over 1,000 megawatts of new capacity to maintain adequacy. Should the Colstrip 1 and 2 coal plants (307 megawatts committed to serve regional demand) also retire before 2021, the LOLP grows to just over 13 percent and the region's adequacy need grows to about 1,400 megawatts of new capacity.

These results are based on a stochastic analysis that simulates the operation of the power supply over thousands of different combinations of river flow, wind generation, forced outages, and temperatures. Since last year's assessment, which resulted in an 8 percent LOLP for 2021, the region's load forecast has remained fairly flat and no new resources have been added to the

¹ Boardman and Centralia 1 coal plants are scheduled to retire in December 2020. However, because the Council's operating year runs from October 2020 through September 2021, these two plants would be available for use during the first three months of the 2021 operating year. For this scenario, the LOLP is 7.6 percent. The Council must take into account the long-term effects of these retirements, and therefore uses the more generic study that has both plants out for the entire operating year.

mix. This year's assessment for 2021 has grown to 10 percent because the analysis included all regional balancing reserve requirements instead of only the federal system reserves.

The conclusions made above assume that future demand will stay on the Council's medium load forecast path and that only a fixed amount of imported generation from the Southwest is available. If demand growth were to increase rapidly and if the availability of imports were to drop, the LOLP could grow as high as 30 percent and the region's adequacy needs could grow to 2,600 megawatts or more. But these extreme cases are not very likely to occur.

Resource acquisition plans to bring the 2021 power supply into compliance with the Council's standard will vary depending on the types of new generating resources or demand reduction programs that are considered. In all likelihood, some combination of new generation and load reduction programs will be used to bridge the gap. It should be noted that developing a strategy to maintain an adequate, efficient, economical, and reliable power supply is beyond the scope of this analysis. Designing a resource strategy to ensure an adequate power supply for 2021 is more appropriately done using the strategy outlined in the Council's Seventh Power Plan.

Northwest utilities, as reported in the Pacific Northwest Utilities Conference Committee's 2016 Northwest Regional Forecast, show about 550 megawatts of planned generating capacity for 2021. However, these planned resources are not sited and licensed and are therefore not included in the 2021 adequacy assessment. As conditions change over the next few years, it is expected that utilities will revise their resource acquisition strategies to ensure that sufficient investments in new resources, which include energy efficiency and demand response, will be made to maintain an adequate supply.


Power Supply Adequacy for the 2021 Operating Year

Council Meeting
Polson, Montana
August 9, 2016

Today's Discussion

- **Adequacy Primer** 20 min
- **2021 Adequacy Assessment** 15 min
- **Council Messages** 5 min
- **Additional Slides** 5 hours

Adequacy Primer



Review: Council's Adequacy Standard


The likelihood of a power supply shortfall anytime during the year in question should not exceed 5 percent.

- Power system operation for 2021 is simulated thousands of times, each time selecting different combinations of river flows, wind generation, temperature and generator forced outages.
- Likelihood of a shortfall is equal to the number of simulations with shortfalls divided by total number of simulations
- Power supply is adequate if the above value is 5% or less


Resource Dispatch Order

Resource	Description	
Firm Hydro and Thermal	From lowest to highest operating cost	Modeled in GENESYS
Non-firm and Markets	In-region and out-of-region markets, surplus hydro, borrowed hydro	
Standby Resources Type 1	Non-declared utility resources (diesel generators, etc.)	Modeled in Post Processor
Standby Resources Type 2	Demand response and buy-back load provisions	
Emergency Action 1	More expensive non-declared resources or contract provisions	Not Modeled, Not part of Assessment
Emergency Action 2	Governor's call for voluntary curtailment of energy	
Emergency Action 3	Rolling black outs or brown outs	


Sample Future Simulation 1



Sample Future Simulation 2



Sample Future Simulation 3





Tally Curtailments by Game

Game	Curtailment (MW)
1	0
2	0
3	500
4	0
5	900
6	100
7	0
8	450
9	0
10	150
...	...
100	0

Tally Curtailments - Graphically

(Step through games and fill curtailment bins)





Sort by Curtailment Size


Game	Probability of Exceeding	Curtailment (MW)
54	1%	950
30	2%	900
18	3%	850
73	4%	800
6	5%	700
22	6%	600
33	7%	450
...
20	32%	10
10	33%	1
...
100	100%	0

Then graph these results

33% of the games have a curtailment, LOLP = 33%

Northwest Power and Conservation Council nwccouncil.org

Peak-Hour Curtailment Probability Curve (for 100-game **sample case**)




Sort by Curtailment Size

Game	Probability of Exceeding	Curtailment + 600 MW
54	1%	950 350
30	2%	900 300
18	3%	850 250
73	4%	800 200
6	5%	700 100
22	6%	600 1
33	7%	450 0
...
20	32%	10 0
10	33%	1 0
...
100	100%	0

6% of the games have a curtailment, LOLP = 6%

2021 Peak-Hour Curtailment Probability (Medium load, no standby – 6,160 games)



2021 Adequacy Assessment





2021 Adequacy Assessment

Year		Status	Capacity Need
2016 to 2020		Adequate LOLP < 5%	None
2021 Case 1	Small net load growth No new sited & licensed resources Lose Boardman & Centralia (1,330 MW)	Inadequate LOLP = 10%	<u>Need</u> <u>Load</u> 1,040 MW – med 2,230 MW – high
2021 Case 2	Retirement of Colstrip 1 & 2 (307 MW of dedicated regional capacity)	Inadequate LOLP = 13%	<u>Need</u> <u>Load</u> 1,360 MW – med 2,560 MW – high

Resource Acquisition Activities

Item	Comments	Source
Planned Resources	550 MW	PNUCC 2016 NRF
Demand Response	600 – 2,700 MW potential Mostly untested acquisition	Seventh Power Plan
Coal Replacement Strategies	Internal utility discussions	Utilities
Additional Wind/Solar	Winter capacity shortage New wind will not help Solar will help minimally	Council studies



2021 LOLP for Both Cases

Case → Loads ↓	No Boardman No Centralia 1	No Boardman No Centralia 1 No Colstrip 1 & 2
High Load	24	31
Med Load	10	13.2
Low Load	4	5.1

Council Messages



Council Messages

- Inadequate status in 2021 was expected
- Loss of Colstrip increases capacity need
- Continued acquisition of EE imperative
- Combination of already planned resources + acquisition of DR could be sufficient
- If needed, region has time to acquire additional generating resources
- Council will assess again next year

Additional Slides (if needed)



2021 Reference Case

(see next 3 slides for more detail)


- **Loads** (from long-term model hybrid method)
 - Long-term model weather-normalized frozen-efficiency monthly loads
 - Add weather-normalized daily and hourly shapes
 - Add 7th plan EE targets by applying monthly effects
 - Add temperature variations from short-term model
- **Demand Response:** Existing + 121 MW planned DR
- **Import availability**
 - Spot (available all hours, winter only)
 - Purchase Ahead (available light-load hours, all year)
- **IPP generation**
 - Full availability (2,943 MW) winter
 - Limited availability (1,000 MW) summer
- **Wind** 4,896 MW nameplate (modeled as Columbia Gorge wind)
- **Solar** 396 MW nameplate, fixed generation pattern

Reference Case Assumptions

Item	Quarter 4	Quarter 1	Quarter 2	Quarter 3
Mean Load (aMW)	21,234	20,975	18,813	19,987
Peak Load (MW)	33,768	33,848	26,504	28,302
DSI Load ² (aMW)	338	338	338	338
Mean EE (aMW)	1,545	1,574	1,274	1,208
Peak EE (MW)	2,660	2,660	1,680	1,680
Spot Imports (MW)	2,500	2,500	0	0
Purchase Ahead (MW)	3,000	3,000	3,000	3,000

²DSI load is 338 aMW in low, med and high load cases in 2021.

Example of Energy Efficiency Savings 2021 Hybrid Loads January (1929 Temp)



Scenarios

- Reference Studies (for heat map)
 - Reference Case (see previous slides)
 - Load Ranges (low, medium and high)
 - Import Ranges (1700, 2500, 3400 MW)
- Sensitivity Studies
 - Reference Case using STM loads
 - Fuel Limitation Case: Reduce winter gas IPP capability by 35% (650 MW), reduces all-fuel winter IPP cap by 22%
 - Reduces winter IPP total cap from 2943 to 2293 MW
 - Reduces summer IPP total cap from 1000 to 779 MW
 - Standby Resource Sensitivity
 - Existing + Planned DR and Emergency Generation
 - Existing + Planned + RPM Minimum DR (500 MW)
 - Existing + Planned + RPM Expected DR (1,257 MW)

Sensitivity Case Loss of gas supply for IPP/ Market friction effect		Loss of 650 MW IPP 2500 MW import		
Ref Case	Standby ↓ Loads	Standby Gen. + exist DR + 121 MW DR	Standby Gen. + exist DR + 500 MW DR	Standby Gen. + exist DR + 1,257 MW DR
24	High Load	30	23	13
10	Med Load	13	10	6
4	Low Load	6	5	3

Northwest Power and Conservation Council 29 nwcouncil.org

Comparison to Past Assessments

Year Analyzed	Operation Year	LOLP	Observations
2010	2015	5%	Was part of the Council's 6 th Power Plan
2012	2017	7%	Imports decreased from 3,200 to 1,700 MW, load growth 150 aMW per year, only 114 MW of new thermal capacity
2014	2019	6%	Load growth 0.6%, over 600 MW new generating capacity, increased imports by 800 MW
2015	2020	5%	Lower load forecast, 350 MW of additional EE savings
2015	2021	8.3%	Early estimate (BPA INC/DEC only) Loss of Boardman and Centralia 1 (~1,330 MW)
2016	2021	10%	2021 loads lower than last year's forecast (~1,500 aMW) but winter peaks are higher (~3,000 MW), using regional INC/DEC reduces hydro peaking by as much as 2,000 MW

Northwest Power and Conservation Council 30 nwcouncil.org