

# System Analysis Advisory Committee

June 23, 2014

# Current SAAC Members

- Clint Kalich, AVISTA
- Mike McCoy, BECKER CAPITAL
- Marty Howard, BMH<sub>3</sub> (CONSULTANT)
- Ehud Abadi, BPA
- Robert J Petty, BPA
- John Scott, EPIS
- Sibyl Geiselman, EWEB
- Kevin Nordt, GCPUD
- Rick Sterling, IDAHO PUC
- Mark Stokes, IDAHO POWER
- Jim Litchfield, LITCHFIELD CONSULTING (CONSULTANT)
- Fred Huette, NW ENERGY COALITION
- Diane Broad, ODOE
- Mike Hoffman, PNL
- Michael Deen, PPC
- Dick Adams, PNUCC
- Sima Beitinjaneh, PORTLAND GENERAL ELECTRIC
- Villamor B Gamponia, PSE
- Phillip. Popoff, PSE
- Dave LeVee, PwrCast
- Mark Dyson, ROCKY MOUNTAIN INSTITUTE
- Tom Chisholm, USACE

# Since the last SAAC...

- Changes to the model have been required based on updated peak load forecast and needs assessment
- Staff have focused on 2021 and 2026 as the critical outcomes for the 7<sup>th</sup> Plan

# Timeline of Load Changes

- After April SAAC, concerns on how peak loads were represented were brought to Council staff by SAAC members
- Council staff upon review revised the peak forecast from using peak load based on weather-normalized load to expected peak load method presented in the May SAAC
- The 7<sup>th</sup> Plan needs assessment was revised to be consistent with the expected peak method

# Timeline of Load Changes

- The ARMs from the needs assessment varied based on the relationship between peak and energy, staff took the average of the ARMs for the 2026 Needs Assessment runs in Genesys as the input for RPM
- New peaks loads made adequacy builds more frequent in the 1B and 2C scenarios, but in many cases the model was hitting a penalty value rather than building

# Timeline of Load Changes

- Through the June Council meeting results presented had substantial penalty payments, caveats were given that there was still work to be done on loads

# Timeline of Load Changes

- Staff found three model drivers for this phenomena
  - Some penalties were unavoidable at the beginning of the study because the resources that could be built, including conservation, were not sufficient to remove the penalties
  - The penalty was set too low at \$1 Million per MW per year, which translated into \$250,000 per quarter whereas the most expensive resource cost just under \$6 Million per MW per quarter
  - The internal agent-based load forecast was biased to under-forecast most peak needs and thus even when options were available to avoid paying penalties, the LP in the model would not build

# Timeline of Load Changes

- Staff revised the model to address issues raised by the updated peak-load forecast methodology

# Model Revisions

- The penalty was changed to only apply to capacity that can be addressed by the resources in the model, i.e. penalties are not added into the NPV unless it's possible for the model to avoid them
  - The model still tends to have some penalty because some build decisions are very expensive, e.g. high-cost conservation

# Model Revisions

- The input penalty was changed from \$1 Million per MW per year to \$24 Million per MW per year
  - This guarantees that paying the penalty **every period** is more expensive than building any of the resources
  - Paying the penalty in one future and for one period could potentially be less expensive than available build options

# Model Revisions

- The internal LP was given perfect foresight rather than an internal load forecast model strictly for adequacy decisions
  - This is seen as an interim change for the draft plan, staff anticipates further refinement for the final

# Model Results

- Generally with these revisions there are
  - More resource builds including demand response and thermals
  - Immediate needs for capacity resources to meet the adequacy standard drives early builds of expensive resources
  - The options coming out the model tend to fall into three categories:
    - Built within every future
    - Built frequently (around 50% of the time)
    - Optioned for a handful of extreme futures


# Critical Water Resource Capacity Winter 2016

Resource Type	MW Capacity
Thermal (Rate-Based)	12174
Wind	221
Critical Hydro	18785
Contracts	-289
<b>TOTAL</b>	<b>30891</b>

# Average Water Resource Capacity Winter 2016

Resource Type	MW Capacity
Thermal (Rate-Based)	12174
Wind	221
Average Hydro	23898
Contracts	-289
<b>TOTAL</b>	<b>36004</b>

# Historic Regional Peak Load



# Gut Check

## Since 2001...


- Added around 6000 MW of natural gas generation, retired around 650 MW
- Reached around 8900 MW of installed nameplate of wind generation (3000 MW for California)
- Gained around 1200 aMW of “historic weather-normalized load”
- Hydro expectation was reduced by around 500 aMW in winter

# Gut Check


Since 2001 for capacity...

- **Rough** estimate of changes to load/resource balance:
  - + 6000 MW
  - - 650 MW
  - + 300 MW (5% wind)
  - - 1500 MW (rough estimate for wind integration)
  - - 500 MW (expected hydro estimate based on energy)
  - - 1550 MW (expected peak estimate)
- Increase of 2100 MW in capacity, estimates in 2001 were that the region was roughly 4000 aMW deficit


# Capacity Loads & Resources 2016-35




# Net System Cost Scenario Comparison




# Load Net of Conservation Scenario Comparison




# 111(d) CO2 Emissions in 2030 Scenario Comparison



# Non-Hydro Dispatch Scenario Comparison




# Non-Hydro Dispatch Scenario Comparison




# Average Conservation Development Across Scenarios Increases When Uncertainty and Carbon Risk Are Considered But Does Not Increase With Full Coal Retirement

## Scenarios 1A, 1B, 2C and 3A – Least Cost Resource Strategies




# This Result is Very Similar To The 6<sup>th</sup> Plan

## Net Load After Conservation Scenarios 1B, 2C and 3A Least Cost Strategy and 6<sup>th</sup> Plan




# The Least Cost Strategies for Scenarios 1B, 2C and 3A Distributions of Conservation Development Through 2021





- Scenario 1B - Existing Policy, No Carbon Risk
- Scenario 2C - Carbon Risk
- Scenario 3A - Maximum Carbon Reduction, Existing Technology


# The Least Cost Strategies for Scenarios 1B, 2C and 3A Distributions of Conservation Development Through 2026



# The Least Cost Strategies for Scenarios 1B, 2C and 3A Distributions of Thermal Resource Development Through 2021 for Capacity



# The Least Cost Strategies for Scenarios 1B, 2C and 3A Distributions of Thermal Resource Development Through 2026 for Capacity



- Scenario 1B - Existing Policy, No Carbon Risk
- Scenario 2C - Carbon Risk
- Scenario 3A - Maximum Carbon Reduction, Existing Technology

# The Least Cost Strategies for Scenarios 1B, 2C and 3A Distributions of Thermal Resource Development Through 2035 for Capacity

